



Workman Commercial
Phone: (512) 326-9293 | Fax: (512) 447-8156
1766 FM 967, Suite B | Buda, Texas 78610
workmancommercial.com

Project: Breakfast Restaurant at Veramendi New Braunfels
Bid due: November 3rd, 2023
Bid time: 3pm

Request for Information/Clarifications

Date: 10-27-23

No	Question	Clarification
1.	Please verify the 2.2 external static pressure for Roof Top Unit (RTU-1) as indicated on the schedule? Carrier stated that their maximum static pressure for the RTU is 2.0.	2.0 Static Pressure will be okay.