



Project: Gardenia Warehouse
Bid due: March 6th, 2024.
Bid time: 2pm

Request for Information/Clarifications

No	Question	Clarification
1.	PEMB: What is the roof insulation and wall insulation?	Roof insulation will be per PEMB (R-38 ceiling and R-19 for the walls)
2.	What are the flooring specifications for the office, restroom and warehouse? A5	The office and restroom floor will be clear seal concrete floor.
3.	The schedule in A5 calls for C-1 in Warehouse but the floor plan says open ceiling. Please clarify.	Open ceiling in the warehouse.