

**July 25, 2024 | Addendum #2 – Narrative**

Revisions to the last drawing set issued on May 30, 2024

Project Name: Super Kids Dental

Project Address: 6707 E Riverside Drive, Unit 201
Austin, TX 78741

Prepared by: Element Architects, LLC
1250 Wood Branch Park Drive, #480
Houston, Texas, 77079
Tel. (713) 874 0775

EA Project #: 24017

Notice to Proposers:

- A. This Addendum forms part of the Contract documents for the above referenced project and shall be incorporated integrally therewith.
- B. Each proposer shall make necessary adjustments and submit his proposal with full knowledge of all modifications, clarifications, and supplemental data included therein. Where provisions of the following supplemental data differ from those of the original Contract Documents, this Addendum shall govern.

MECHANICAL: (All drawings are dated 07/16/24, revision delta 2)**SHEET M101 – MECHANICAL FLOOR PLAN**

- a. Removed the Exhaust fan in the med gas room per the Mechanical reviewer's request.

SHEET M301 – MECHANICAL SCHEDULES

- a. Fan EF-03 has been removed from the mechanical fan schedule.

ELECTRICAL: (All drawings are dated 07/16/24, revision delta 2)**SHEET E101 – ELECTRICAL FLOOR PLANS**

- a. The service receptacle for AHU-1 has been revised to be GFCI protected.

SHEET E201 – ELECTRICAL RISER DIAGRAM

- a. The service grounding detail has been revised to accurately reflect the service, and the size of the ground for our space has been labeled. Also added an additional wire size callout on the riser diagram.

END OF ADDENDUM #2 NARRATIVE