



Workman Commercial
Phone: (512) 326-9293 | Fax: (512) 447-8156
1766 FM 967, Suite B | Buda, Texas 78610
workmancommercial.com

Project: Square at Crystal Falls-Leander Texas
Bid due: September 5th, 2024
Bid time: 12pm

Request for Information/Clarifications

No	Question	Answer
1	What is the size of the stone ST-1 called out in the plans? A201	For the stone, we would prefer an 8" min. We are open to other stone quarry or manufacturers than the one listed on A201, but would like to keep white and smooth cut face finish for a clean modern aesthetic.
2	What is the specification for Aluminum tongue and groove soffit? A311	For the aluminum soffits, we had looked at Knotwood's soffit in a standard wood finish - https://knotwood.com/systems/soffits/ .